

The Building Regulations 2000

Ventilation

APPROVED DOCUMENT

Amendment to 2006 edition



Amendments to Approved Document Part F 2006 edition

1. Inside front cover

Delete penultimate paragraph:
'Replacement windows should....provided in the same room.'

2. Page 10

In paragraph 1.4, at the end of line 5, after 'on-site' insert "except where necessary to balance the system" but the performance... Table 1.6.

3. Page 19

Table 1.6, Note 1, line 4, change 'many' to 'may'.

4. Page 28

In paragraph 3.3, line 2 delete "and 3.1(A)"

Delete paragraph 3.4 and replace with the following:

'3.4 Where the original windows were fitted with trickle ventilators the replacement windows should include them and they should be sized as set-out in paragraph 3.6. It would be good practice to fit trickle ventilators (or equivalent), with accessible controls, in all replacement windows to help with control of condensation and improve indoor air quality.'

Delete paragraph 3.5 and replace with the following:

3.5 'When windows are replaced as part of the work connected with a material change of use sections 1 and 2 of this Approved Document apply.'

Page 28

In the heading: **Addition of a habitable room (not including a conservatory) to an existing building**, change 'building' to 'dwelling'

5. Page 29

In the heading; **Addition of a wet room to an existing building**, change 'building' to 'dwelling'

6. Page 36

In the second bullet change 'dwelling' to 'building'.

7. Page 38

Left hand column, second bullet

Replace 'less than 30°' with 'between 15° and 30°'

© Crown Copyright 2007

Copyright in the contents, cover and the typographical arrangement of this publication rests with the Crown unless otherwise stated. The contents of this publication may be reproduced free of charge in any format or medium for the purposes of private research and study or for internal circulation within an organisation. This is subject to the contents being reproduced accurately and not in a way that implies official status. Any publisher wishing to reproduce or replicate the content of this publication must not use or replicate the Communities and Local Government logo or replicate the official version's style and appearance, including cover design, and must not present their publication as being an official publication as this may confuse the public.

The reproduced material must be acknowledged as Crown Copyright and the title of the publication specified. The Department for Communities and Local Government does not accept any responsibility for the accuracy and comprehensiveness of any other versions.

Any other use of the contents of this publication would require a copyright licence. Please apply for a Click-Use Licence for core material at www.opsi.gov.uk/click-use/system/online/pLogin.asp, or by writing to the Office of Public Sector Information, Information Policy Team, St Clements House, 2-16 Colegate, Norwich, NR3 1BQ. Fax: 01603 723000 or email: HMSOLicensing@cabinet-office.x.gsi.gov.uk